

User Manual

Heated Digital Water Bath

Applicable Models : WB200D, WB500D, WB1100D, WB1700D

Version: 1.0 – 29/02/2016

English



www.ratek.com.au

60 Wadhurst Dve, Boronia, Victoria 3155, Australia - P: +613 9887 2161 - F: +613 9887 2163 - E: sales@ratek.com.au

© All Rights Reserved

Made in Australia, User Manual printed in Australia
Changes without prior notification reserved
Errors and omissions excepted.

Thank you

Thank you for purchasing a Ratek product.

This User Manual will assist you in the correct installation and operation of the WBx000D Series Water Bath, as well as explain the safety requirements for its use.

Important: Please read the contents of this User Manual before unpacking and operating the product.

Unpacking and Checking

Once you have read these instructions in full and understand the installation and safety requirements including those for unpacking the carton, please carefully open the packing and slowly remove the product. Carefully inspect the condition of the product to ensure it has not been damaged in transit. Any damage should be reported immediately to the responsible carrier. If the product is damaged in any way, re-pack the product into the supplied packaging and notify the responsible carrier immediately.

Important: Do not operate the equipment if it has been damaged in any way. Any failures resulting through the use of a damaged product will not be covered by the product warranty.

Carton Contents

Ensure that you have received all items outlined below before proceeding. If you have not received all components in the supplied carton, please re-pack the carton and notify a Ratek Service representative immediately. Contact details are provided in the section of this User Manual titled "Ratek Service Contact Information"

- **Ratek WBx000D Series Water Bath**
- **Mesh Platform**
- **IEC mains power cord**
- **User Manual**

TABLE OF CONTENTS	PAGE
INTENDED USE	4
Suitable Articles For Use With This Water Bath.....	4
Unsuitable Articles For Use With This Water Bath	4
Suitable Environments For The Water Bath.....	4
General Operation	4
OPERATOR RESPONSIBILITY – SAFETY CONSIDERATIONS	4
Conditions of Operation	4
Safety Labels And Markings	5
OPERATING PROCEDURES	6
Identification of Controls & Functions	6
Safety Warnings	7
Safety Recommendations.....	7
Preparation & Installation	8
Using The Water Bath	10
ROUTINE CLEANING AND MAINTENANCE.....	15
TECHNICAL SPECIFICATIONS	18
DISPOSAL	18
EMC CONFORMITY.....	18
RATEK SERVICE CONTACT INFORMATION.....	19
TROUBLESHOOTING.....	19
WARRANTY CONDITIONS.....	20

Intended Use

This water bath is intended for the purpose of heating water only. The operator may load a suitable article onto the mesh platform for the purpose of controlled temperature application. The water bath is intended for use with tap water or filtered water only.

The water bath is **not** intended for use with any other medium. The water bath is **not** intended to provide direct-contact between the medium (water) and an unprotected medical, food, biological or medico- techno item. In all cases the item should be enclosed in a suitable vessel as described below.

Suitable Articles For Use With This Water Bath

- Plastic or glass laboratory test tubes that are sealed, waterproof and rated to withstand the intended temperature.
- Plastic or stainless steel laboratory test tube racks that are rated to withstand the intended temperature.
- *An example of a suitable article would be a sealed plastic laboratory centrifuge tube filled with blood.*

Unsuitable Articles For Use With This Water Bath

- Any item where the article is not waterproof or may result in its contents coming into contact with the water bath medium (water).
- Items weighing more than 3 kilograms.
- *An example of an unsuitable article would be an exposed piece of animal or plant matter.*

Suitable Environments For The Water Bath

The water bath is intended for use in a clean laboratory environment only where adequate ventilation, a good power supply and provisions for routine cleaning are available. The water bath should not be used outdoors or in dirty, dusty, humid or windy environments. The acceptable operating conditions are outlined further in this User Manual.

General Operation

- The water bath is filled with water following the safety guidelines contained within this User Manual.
- The water bath is plugged into an appropriate power source. It is powered by an alternating current power supply with protective earth and with the appropriate receptacle, rated voltage and frequency for the country of its intended use. Further details on power requirements are outlined in this User Manual.
- A suitable article (as defined above) is placed on the mesh platform.
- The water bath is operated via a front panel interface consisting of heating temperature control buttons plus digital display and an on/off switch located at the rear of the bath. These controls allow the operator to set a required water temperature.
- The water bath should be operated strictly in accordance with the Operating Procedures outlined further in this User Manual.

Operator Responsibility – Safety Considerations

When operated in strict accordance with this User Manual, plus routine cleaning and maintenance being carried out, the product shall provide safe operation for the operator. The operator should be aware of the following before installing and operating the product :

Conditions of Operation

***Note:** The term “operator” referred to in this User Manual is the primary person who has been tasked to install, maintain and train in the usage of this equipment. Other personnel shall be referred to as “Users”.

- The operator shall be aware that the protection provided by the equipment may be impaired if the equipment is used with accessories not provided or recommended by the manufacturer, is modified in any way or is used in a manner not specified by the manufacturer.
- The operator is responsible for ensuring all users of the product are qualified to do so, and are well versed in common safety concepts. The product should only be operated by an adult who has read and understood this User Manual provided in the appropriate language in its entirety.
- Any user must be informed by the responsible operator of any potential hazards that may arise through the use of this equipment in the course of their work, including any local environmental hazards not related directly to the water bath. They should also be able to demonstrate that they understand any preventative safety measures in operation prior to operating the equipment.
- The operator shall agree to accept responsibility for the use of the equipment in accordance with this User Manual, and be fully aware that the equipment is designed for commercial use.
- It is assumed that the user and operator have had experience in a commercial environment, and had appropriate training in how to perform their work safely in accordance with any local operational health and safety regulations. The operator and all users should be well versed in local emergency procedures as per the workplace safety regulations in effect.

- Avoid any direct impact with any surface of the equipment. This includes the casing and most importantly the control panel.
- **Important:** Do not use any sharp or pointed metal objects anywhere near the equipment, in particular the control panel.
- Avoid using the equipment near any other vibrating equipment or source of excessive vibration.
- Ensure the equipment is cleaned and maintained in accordance with this User Manual.
- Ensure that all original safety warning labels are in an adequate, legible condition and are firmly affixed to the equipment before using the product.
- Plug the equipment directly into a wall power outlet. Do not plug the equipment into a multi-socket adapter of any kind.
- The equipment is intended for operation in a controlled electromagnetic environment. Avoid the use of transmitting devices (e.g. cellular or mobile telephones) near the equipment whilst operating. A minimum distance of 2 Metres from the product is recommended for any transmitting device.
- The equipment must only be installed and operated in well ventilated areas. The unit is not intended for use in explosive atmospheres, in confined spaces or inside any other piece of laboratory equipment such as humidity cabinets or incubators.
- The allowed operating environment is between 5° Celsius and 40° Celsius ambient air temperature. Be aware that the ambient air temperature will limit the minimum controllable water temperature. The ambient air temperature must be at least 5° Celsius lower than the desired controllable water temperature.
- The maximum allowed relative humidity of the operating environment is 80%.
- The equipment should not be stored in direct sunlight, near chemicals, or other contaminants.
- If any of these safety recommendations cannot be achieved or the equipment has been damaged in any way, the equipment should not be installed or operated.
- **Important :** If you have any concerns or questions relating to operator or user safety, please contact the appropriate Ratek Service department before installing and operating the unit. Contact details are provided in this User Manual.

Safety Labels And Markings

The equipment is provided with safety caution labels. An explanation of each caution label is provided below. It is the responsibility of the operator and user to fully understand the meaning of these warning labels prior to operating the equipment.

Very Important: Particular care should be taken when working near the heating element in the bottom of the water bath. At all times during operation the mesh platform MUST REMAIN FITTED to the water bath to avoid possible burns or scalds from the heating element.

The operator or user must also take extreme care when the bath is working at temperatures above 50° C as steam will be present and can cause scalding.

Caution Labels



Colours: Black on a yellow background

Definition

The Water Bath is powered by an alternating current power supply sufficient to cause harm if contact with the electrical supply is made. Under no circumstances should any part of the equipment be opened, un-screwed, loosened or disassembled whilst power is applied to the unit. Only authorized service agents are permitted to remove covers. This label is fitted by the manufacturer and must not be removed under any circumstances.



Colours: Black on a yellow background

The Water Bath is fitted with a removable guard which protects against contact with the heating element. This guard **MUST REMAIN FITTED** at all times during operation. Under no circumstances should the heating element be touched whilst in operation. This label is fitted by the manufacturer and must not be removed under any circumstances.



Colours: Black on a yellow background

The Water Bath is designed for heating water to temperatures that can cause burns or scalding. Use extreme caution when working near hot water or steam to avoid injury. Under no circumstances should the heating element be touched whilst in operation. This label is fitted by the manufacturer and must not be removed under any circumstances.

Operating Procedures

You must take the time to familiarize yourself completely with the following operating procedures before installing or operating the water bath in order to achieve the best performance and maximum attainable user safety.

Identification of Controls & Functions

Throughout this User Manual, the numerical element representing a control or component of the water bath will be used to identify it. The figure below indicates all key controls and components of the water bath with their corresponding numerical element labeled.







Figure 1

Figure 1 (Model WB1700D pictured, the water tank size of other models vary)

Safety Warnings




Throughout this User Manual, specific warnings will be supplied which relate to the current operation being referred to. These warnings are supplied in addition to the main warning labels affixed to the product and the key points outlined in the section of this User Manual titled 'Operator Responsibility – Safety Considerations'.



A graphical symbol as pictured below will be used next to each warning with accompanying text, the danger level for each is described below :

	<p>CAUTION Indicates a possibly dangerous situation which may result in serious injury or threat to life if the situation is not avoided.</p>
	<p>CAUTION Indicates a possibly highly dangerous situation which may result in serious injury or threat to life if the situation is not avoided.</p>
	<p>CAUTION Indicates a possibly harmful situation which may result in injury or damage to product or property if the situation is not avoided.</p>

Safety Recommendations



The following safety recommendations must be followed to prevent damage or injury. In addition to these safety recommendations, it is assumed that the user and operator have had experience in a commercial environment, and had appropriate training in how to perform their work safely in accordance with any local operational health and safety regulations. The operator and all users should be well versed in local emergency procedures as per the workplace safety regulations in effect.





	<p>CAUTION If the equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.</p>
	<p>CAUTION The equipment must only be used with a protective earth power socket. The earth contact provides protection to the user and the equipment. If you do not have a protective earth power socket, or you are unsure as to whether you have a protective earth power socket, do not connect the equipment. In such cases you should consult your workplace administrator or electrical maintenance staff to determine if a protective earth power socket is available.</p> <p>A surge protected power outlet is strongly recommended as it provides some protection for the equipment in areas of poor electrical quality as well as providing some protection against lightning strikes. The equipment should be operated on a good, reliable supply of power at all times.</p> <p>Note: The water bath should not be operated on the same electrical circuit as other high voltage household appliances such as fridges, clothes dryers, washing machines or other continuous operation high voltage devices. These types of devices can create power fluctuations that are undesirable for electrically sensitive equipment. Consult your workplace administrator or electrical maintenance staff if you are unsure.</p>
	<p>CAUTION The water bath is intended for use with tap water or filtered water only. De-ionized or distilled water can cause corrosion.</p> <p>Use with any other medium including corrosive cleaners and anti-fungal agents is not permitted.</p> <p>The use of flammable liquids may cause serious injury or danger to life.</p>

	<p>CAUTION Always work above the level of the water bath to avoid spillage of dangerously hot water. At no point should the user, operator, animal or any other perishable object be situated directly beneath the water bath.</p>
	<ul style="list-style-type: none"> - ALWAYS wear protective eyewear when working with hot liquids. - ALWAYS place the water bath on a strong, even, dry, flat waterproof surface which is made of inflammable material. Placing the water bath on an unstable surface could cause hot water to spill. - ALWAYS empty the water bath before moving the equipment to a new location. - ALWAYS turn off the mains power switch (element 6 in Figure 1) when the unit is not in operation and turn off the mains power supply at the outlet. - ALWAYS turn off the mains power switch (element 6 in Figure 1) and unplug the equipment from the mains power supply outlet before emptying the water tank or moving the equipment. - ALWAYS be careful of water condensation above or near the water bath and ensure at all times that the condensation cannot come in contact with the water bath control panel or mains power lead. Ensure benches are kept dry at all times. - ALWAYS operate the water bath in a well ventilated area with adequate clearance around the water bath as indicated. - ALWAYS be careful of steam and avoid making contact. - NEVER operate the water bath without water in the water tank. - NEVER empty the water bath while it contains hot water. Always allow the water to cool to ambient room temperature before emptying. - NEVER operate the equipment if you believe it is damaged in any way. - NEVER operate the water bath if the mains power supply cable is damaged in any way - NEVER use any sharp or metal objects near the water bath control panel. - NEVER lift the water bath if you have an existing injury that impairs your ability to lift.

Preparation & Installation




The water bath should be installed and operated in strict accordance with the following instructions.




	<p>CAUTION The water bath is not for use in explosive atmospheres as there is a risk of fire, explosion, burns or scalding present under these conditions.</p>
	<p>CAUTION Be careful when lifting and observe your local operational health and safety requirements for lifting before unpacking the carton.</p>
<p>Unpacking and Installing</p>	
	<ul style="list-style-type: none"> - Carefully remove all packaging material from the water bath, as well as the supplied User Manual and any other supplied accessories. - Carefully inspect the water bath, mains power lead and all packaging for any signs of damage. If any signs of damage are present, do not install or operate the equipment. Contact the supplier of your equipment if you have a received a damaged product. - Place the water bath in an upright position as per Figure 1 on a strong, even, flat waterproof surface which is made of inflammable material. - Ensure that there is a minimum unobstructed distance of 100 millimetres between the left, right and rear panels of the water bath and any other object or wall. - Ensure that there is a minimum unobstructed distance of 500 millimetres above the top of the water tank to allow for adequate ventilation. - Ensure that there is a suitable mains power supply outlet within reach of the supplied mains power lead without placing any





	<p>strain whatsoever on the lead, socket or plug. The water bath should not be plugged into any double-adaptor, power board, or power point splitter of any kind but instead directly into a correctly earthed wall mounted power socket.</p> <ul style="list-style-type: none"> - Ensure that there is a minimum unobstructed distance of 1,000 millimetres in front of the water bath to allow adequate room for the user to maintain a safe operating distance of 300 millimetres. - Carefully insert the mesh platform into the base of the water tank with the flat side up. The mesh platform covers the heating element (concealed beneath the tank) and provides protection from the heat it generates.
	<p>CAUTION The water bath is designed for the purpose of heating immersed plastic or glass sealed laboratory test tubes, flasks or bottles suitable for use at the water temperature selected by the operator.</p> <p>The contents of these test tubes is the sole responsibility of the user or operator, and the use of corrosive, flammable, combustible, hazardous, environmentally unsafe or otherwise dangerous materials within the immersed container is done so at the risk and liability of the user or operator.</p> <p>ALWAYS be 100% sure of the contents of your containers, the expected behavior once heated and the applicable safety measures that should be employed when handling such substances.</p> <p>ALWAYS ensure your containers are firmly sealed and there is no chance of the sample leaking into the water bath.</p> <p>ALWAYS use plastic, stainless-steel or plastic powder-coated tubes racks and accessories in the water bath. This will assist to prevent corrosion and thus help to extend the useful life of the water bath.</p>
	<p>CAUTION Poor water quality can lead to corrosion of the water bath even though it is constructed from stainless steel, and eventually lead to a potentially hazardous situation. The water bath is intended for use with tap water or filtered water only.</p> <p>A soft, decalcified water is the recommended liquid for use with the water bath.</p> <p>Depending on local conditions, the water supply may be ferrous or overly chlorinated. Both of these conditions may lead to corrosion if used with the water bath.</p> <p>Distilled or de-ionized water may lead to corrosion if used with the water bath.</p> <p>Use of any liquid (including corrosive anti-fungals and cleaners) other than that recommended above will void the product warranty.</p> <p>Contact the supplier of your water bath before filling the water tank if you are unsure of your water supply.</p>
	<p>CAUTION Before filling the water tank, ensure the mains power supply outlet is switched off and that the mains lead is unplugged from the mains power supply outlet.</p> <p>The nature of pouring water is unpredictable and should be done carefully away from any electrical supply to avoid the risk of electric shock.</p>
	<p>CAUTION Do not over-fill the water bath. If the water bath is over-filled, water may spill out of the water tank and create a hazardous situation if the water comes near an electrical current.</p> <p>The maximum water depth is 25 millimetres below the tank rim.</p> <p>The minimum filling level is 50 millimetres above the mesh platform.</p>





	If the water level falls below this minimum level during operation, the water bath should be powered off, disconnected from the mains electrical supply and the water level topped up with cold water. Be aware that this will result in the rapid decrease in the water bath water temperature and the effect of this in relation to the current procedure being carried out must be considered.
--	---

Using The Water Bath

	Filling The Water Tank
	<p>CAUTION</p> <p>It is important that the mesh platform always remain in place during operation to provide protection from the heat generated by the heating element. Operating the water bath without the mesh platform creates a hazardous situation sufficient to cause burns or scalding if contact with the element is made.</p> <p>IMPORTANT: Do not fill or operate the water bath unless the mesh platform has been fitted.</p>
	<ul style="list-style-type: none"> - For models fitted with a drain tap (WB1100D, WB1700D), ensure the tap is in the closed position before filling. - The water bath should be filled by slowly pouring cold water (below 25° Celsius) into the end of the water bath furthest from the control panel until the desired working level is reached. - Avoid splashing as much as possible.
	Connecting Power
	<p>CAUTION</p> <p>The equipment must only be used with a protective earth power socket. The earth contact provides protection to the user and the equipment. If you do not have a protective earth power socket, or you are unsure as to whether you have a protective earth power socket, do not connect the equipment. In such cases you should consult your workplace administrator or electrical maintenance staff to determine if a protective earth power socket is available.</p> <p>The mains power supply must be rated to match the power requirement as identified on the product identification label on the rear panel. A surge protected power outlet is strongly recommended as it provides some protection for the equipment in areas of poor electrical quality as well as providing some protection against lightning strikes. The equipment should be operated on a good, reliable supply of power at all times.</p> <p>Note: The water bath should not be operated on the same electrical circuit as other high voltage household appliances such as fridges, clothes dryers, washing machines or other continuous operation high voltage devices. These types of devices can create power fluctuations that are undesirable for electrically sensitive equipment. Consult your workplace administrator or electrical maintenance staff if you are unsure.</p> <p>IMPORTANT : Use of an incorrect power supply will void the product warranty waive all liability for any and all damage caused by such use. If you are unsure about the rating of your power supply, consult your workplace administrator or electrical maintenance staff to determine if your power supply is suitable for use with this product before connecting the power lead.</p>
	<p>CAUTION</p> <p>Regularly check the mains power lead condition over the life of the product, and do not operate the equipment if you suspect there is damage to any part of the equipment or the mains power lead.</p> <p>Do not operate the equipment if you suspect the power lead has been stretched, over-extended or damaged in any way.</p>
	<ul style="list-style-type: none"> - Ensure your hands are dry before connecting power. - Insert the female IEC end of the cable firmly into the socket on the rear of the waterbath and ensure a good fit. - Insert the plug end of the mains power supply lead firmly into a properly rated, protective earthed wall mounted power supply outlet. <p>If there are double-adapters or oversized DC power packs causing obstruction of the mains power lead plug, these should first be removed.</p>

	Switching On The Water Heating
	<p>CAUTION Ensure you have filled the water bath to at least the minimum required level before switching on power to the heating system. Failure to do so may create a hazardous situation that can cause burns, scalding and create a fire risk. Ensure the mesh platform is fitted at all times during operation.</p>
	<ul style="list-style-type: none"> - Before switching on the water heating, determine the temperature you wish to operate the bath at. - If you wish to heat your containers from ambient temperature, you should load containers onto the the mesh platform prior to switching on the heating system, see the section titled “Loading the Water Bath” below. - If you wish to add your containers to warm or hot water, this should be done with extreme care once the temperature of the water bath has stabilized.
	<ul style="list-style-type: none"> - Once you are ready to begin heating the water, switch the On/Off mains power switch (element 6 in Figure 1) down to the position marked with a vertical line. The power indicator (element 7 in Figure 1) will light up. - If the last set temperature is greater than the current water temperature, the Heating Element Indicator (element 8 in Figure 1) will light up and either flash to indicate intermittent heating or remain lit constantly to indicate constant heating.
	<p>CAUTION Once the Hot Surface Indicator (element 10 in Figure 1) is lit, the heating element has achieved a temperature sufficient to cause burns or scalding. Once the Heating Element Indicator has lit, under no circumstances should you remove the mesh platform or place any part of your body near the heating element. The residual heat of the element creates a hazardous situation sufficient to cause burns or scalding if contact with the element is made.</p>
	Setting the Required Water Temperature
	<ul style="list-style-type: none"> - The water heating control circuit will retain the last used temperature set-point set on the control panel, so for many applications it will only ever need to be set once. - The LCD temperature display (element 4 in Figure 1) indicates the current water temperature in degrees Celsius in its default operating mode. - Quickly pressing either the up or down temperature control buttons (element 5 in Figure 1) will temporarily display the currently configured temperature set-point without altering it. - To change the set-point, hold either of the temperature control buttons, the longer the press the faster the rate of change. The set temperature on the LCD temperature display will alter. - Once the adjustments have been made, the LCD temperature display will return to show the current water temperature after a few seconds. - If the last set temperature is greater than the current water temperature, the Heating Element Indicator (element 8 in Figure 1) will light up and either flash to indicate intermittent heating or remain lit constantly to indicate constant heating. - Once the water temperature nears the set point, the PID temperature control circuit will start to intermittently engage the element to reduce the rate of heating. - It is normal for the water temperature to exceed the set point slightly in un-circulated baths whilst the temperature stabilizes. The bath temperature will gradually drop back to the desired set-point as the water temperature equalizes. Temperature stability will suffer with insufficient water in the bath.
	<p>CAUTION If the temperature of the water in the water bath is critical to your application, ensure the water bath is left for at least 30 minutes to stabilize after the temperature has reached the set-point before you insert your containers and samples into the water. Verify the water temperature using a thermometer.</p>





	<p>CAUTION Temperatures above 50 degrees are sufficient to cause steam and are also capable of causing burns or scalding. Exercise extreme care paying particular attention to steam and splashing of water when the water bath is operating at these high temperatures, particularly whilst loading and unloading, containers, racks or accessories. ALWAYS use appropriate tools (such as silicon insulated tongs) to lower such containers into the water to avoid your hands coming into contact with hot water.</p>
<p>Loading/Un-Loading the Water Bath</p>	
	<p>CAUTION NEVER load items into the water bath if the mesh platform is not fitted. The mesh platform must be fitted during operation.</p> <p>ALWAYS load items ONLY onto the mesh platform.</p> <p>NEVER touch the bottom of the water tank whilst the water bath is heating as serious burns and scalding could result.</p> <p>ALWAYS use appropriate tools (such as silicon insulated tongs) to load and unload items from the water to avoid your hands coming into contact with hot water or the heating element.</p>
	<p>CAUTION If using the bath with a lid, be careful when lifting the lid as steam may be present.</p> <p>ALWAYS remove the lid at arm's length with your face away from the water bath.</p> <p>ALWAYS use a safety glove when removing the lid as the lid may be hot enough to cause burns or other injury.</p> <p>NEVER remove the lid with your face directly over the water bath. Steam may be present and burns or injury could result.</p>
	<p>CAUTION Be careful when working with hot items removed from the water bath as burns or scalding may occur if contact occurs.</p> <p>Always wear eye protection when loading or unloading items from a hot water bath.</p> <p>Do not use explosive or volatile containers with this water bath.</p> <p>Ensure all containers remain tightly sealed at all times whilst loading and unloading the water bath.</p> <p>Only use containers suitable for the water temperature selected.</p>
<ul style="list-style-type: none"> - When loading, use appropriate tools (such as silicon insulated tongs) to slowly place the required rack, container or accessory onto the mesh platform. Ensure the item will not tip over and will not float. If containers will not stand securely on the mesh platform or will float, a suitable rack, tray or weight should be used which will prevent the container from floating or tipping over. - When unloading, use appropriate tools (such as silicon insulated tongs) to slowly remove the items and place them onto a water-proof and heat-proof surface. - Continue to load or unload your containers, racks or accessories until complete. 	
<p>Switching Off The Water Heating</p>	
<ul style="list-style-type: none"> - Ensure your hands are dry before touching any switches. - Switch the On/Off mains power switch (element 6 in Figure 1) up to the position marked with a circle. 	



	<p>CAUTION</p> <p>Although the heating system may now be inactive, the residual heat in the heating element may be sufficient to cause serious burns or scalding.</p> <p>The residual water temperature may also be sufficient to cause burns or scalding.</p> <p>Allow at least 10 minutes after switching off the heating system to allow the heating element to cool.</p> <p>Allow the water temperature to reach ambient room temperature before proceeding to empty the water tank.</p>
<p>Emptying The Water Tank</p>	
	<p>CAUTION</p> <p>Important: Do not empty the water tank while the water is hot as burns or scalding may result. Allow the water temperature to reach ambient room temperature before proceeding to empty the water tank.</p>
<ul style="list-style-type: none"> - Ensure the water heating has been turned off by pushing the On/Off mains power switch (element 6 in Figure 1) up to the position marked with a circle. - Unplug the equipment from the mains power supply outlet. - Remove all containers, racks and accessories from the water tank and place them in a safe place. - Remove the mesh platform. - If emptying the water into another container, ensure the container is placed below the level of the water bath on a firm, hard, flat surface. - If emptying into a sink or drain, ensure you have clear and unobstructed access to it. - If the bath is fitted with a drain tap (models WB1100D & WB1700D) ensure you have a large enough container to hold all of the water you wish to empty. A 10 mm internal diameter hose may be fitted. - Important: The tap handle may be warm if the bath has been used at high temperatures and should be allowed to cool before emptying. Keeping your hands away from the drain outlet, slowly turn the tap handle to the open position on the front panel and allow the water to empty as indicated below. Gently lift the rear of the bath to assist with final draining. Close the tap once the water flow stops. 	
<div style="display: flex; justify-content: space-around; align-items: center;"> <div style="text-align: center;"> <p>CLOSED</p>  </div> <div style="text-align: center;"> <p>OPEN</p>  </div> </div>	
<ul style="list-style-type: none"> - To empty all remaining water, the water bath should be lifted in accordance with any local operational health and safety guidelines in place. - The water must be emptied towards the rear right corner to avoid water splashing near the power inlet. Slowly increase the lift angle of the bath until all water has emptied from the tank. - Slowly lower the water bath back down to the flat surface until it is fully supported by the surface before letting go. Do not drop the water bath. - Allow the remaining water to evaporate, or use a soft dry cloth to dry around the water bath water tank. 	


	<ul style="list-style-type: none"> - Important: Using a soft dry cloth, dry around the control panel and rear power inlet socket if this has become wet. - Dry your hands before operating any electrical equipment. - Important: Re-fit the mesh platform.
	<p>Over Temperature Safety Cutout</p>
	<p>The water bath features an intelligent manually reset over-temperature safety cutout which cuts power to the heating element in cases where the heating element has become too hot as a result of an insufficient water level being maintained in the bath or an unsuitable heating medium being used.</p> <p>When the cutout activates, the Hot Surface Indicator (Element 10 in Figure 1) will begin flashing and a small click sound may be heard. Power has been cut to the heating circuit.</p> <p>Depending on the quality of the water being used, an unpleasant smell may also be noticed as a result of the impurities in the water becoming hot. This is normal.</p>
	<ul style="list-style-type: none"> - If the over-temperature cutout activates, turn off power to the water bath by setting the On/Off mains power switch (element 6 in Figure 1) to the up position marked with a circle. - Refill the water tank by referring to the section in this User Manual labeled “Filling The Water Tank” and allow 1 minute for the bath to cool. - The water bath can now be re-operated as per the section of this User Manual labeled “Switching On The Water Heating”. - If the Hot Surface Indicator continues to flash after power on, turn the power back off and allow the bath to cool for 5 minutes before turning it back on.
	<p>Storing & Relocating The Water Bath</p>
	<p>CAUTION Be careful when lifting and observe your local operational health and safety requirements for lifting before relocating the water bath. Ask for help if you are unable to move the water bath by yourself.</p>
	<p>The water bath should be stored out of direct sunlight at an ambient temperature below 30° Celsius in a clean and dry location which meets the environmental conditions required as detailed in the technical specifications of this User Manual.</p> <ul style="list-style-type: none"> - Turn off the On/Off mains power switch (element 6 in Figure 1). - Unplug the equipment from the mains power supply outlet. - If the water bath is empty, clean and dry, you may relocate it to an appropriate storage location. - Important: If the water bath is filled with water, it should not be moved for storage. Empty and dry the bath before relocating it. - Ensure the water bath is stored in a clean and dry location away from potential damage by accidental knocks and bumps.

Routine Cleaning And Maintenance

To maintain the water bath in good, safe working order and ensure maximum product lifespan, regular cleaning and general maintenance is required. The water bath should be cleaned at least once every week for a unit being used on a daily basis, for infrequently used water baths a cleaning frequency of once every month is recommended. On each occasion, the general maintenance routine should be employed following cleaning with the exception of the over-temperature safety cutout test which need only be conducted every 2 years of normal operation.

Cleaning The Water Bath	
	<p>CAUTION</p> <p>If the water bath has been operated recently the heating element may be hot enough to create a hazard sufficient to burn or scald if contact is made. Ensure the water bath is empty before cleaning.</p> <p>Allow the water bath to cool for at least 20 minutes after it has last been operated prior to starting the cleaning procedure.</p>
	<p>CAUTION</p> <p>Do not use alcohol based cleaners or solvents on the water bath as these may break down certain components of it's construction, reducing it's life and potentially creating a hazardous situation. Use only a mild household detergent when cleaning the water bath.</p>
	<p>CAUTION</p> <p>If the water bath has been used with any dangerous, chemical or biological substances it should be decontaminated prior to cleaning. Decontaminate the water bath using a decontamination procedure appropriate to the contaminant, however in all cases ensure the following :</p> <ul style="list-style-type: none"> - No decontamination or cleaning agents are used which could cause a hazardous situation to arise as a result of a reaction with parts of the water bath or with any materials contained in it. For example, substances that may compromise the integrity or function of electrical insulation, electrical components, stainless steel components or water seals. - Ratek and the manufacturer are consulted prior to decontamination or cleaning being undertaken if there is any doubt about the compatibility of decontamination or cleaning agents with parts of the water bath or with any materials contained in it.
	<p>CAUTION</p> <p>When cleaning the unit, only use a damp sponge. Do not use a sodden wet sponge. Do not make any part of the control panel, any exposed control or receptacle or any part of the water bath excessively wet. If these receptacles and controls remain wet once electrical power is restored they can create a hazardous situation sufficient to cause serious injury or risk to life due to electrical shock. Always ensure the unit and in particular all controls and switches are completely dry before restoring electrical power.</p>
	<ul style="list-style-type: none"> - Turn off the On/Off mains power switch (element 6 in Figure 1). - Unplug the equipment from the mains power supply outlet. - Empty all water from the water tank as per the section of this User Manual titled "Emptying The Water Tank". - Allow the water bath to air dry, or use a dry cloth to remove water from all surfaces. - Remove the mesh platform. - Using a mild detergent and damp sponge, clean around the sides of the water tank as required. Pay particular attention to any loose particles that may lead to or accelerate corrosion. Impurities out of your water supply may leave corrosive sediment behind, it is important to remove these before returning the bath to operation. A soft dish scourer or metal polish (eg Brasso) is generally sufficient for this purpose, be careful not to scratch the stainless steel of the water tank. The resulting tank should be clean and clear with no visible brown spots or "halos" which are sediment particles sitting on top of the tank surface. These particles can lead to corrosion if left unchecked.

	<ul style="list-style-type: none"> - Once the water bath is clean, use a soft dry cloth to dry all surfaces of the water bath paying particular attention to any controls or switches. - Re-fit the mesh platform. <p>Once cleaning has been completed, it may be re-installed and operated in accordance with this User Manual.</p>
	<p>Maintenance</p>
	<ul style="list-style-type: none"> - Turn off the On/Off mains power switch (element 6 in Figure 1). - Unplug the equipment from the mains power supply outlet. - Under good light, carefully inspect the mains power lead and check for any signs of wear, over-extension or damage. If you believe the lead to be damaged in any way, contact your supplier to arrange for service. - Carefully check to ensure all safety warning labels are affixed and in a good readable condition. Refer to the section in this User Manual titled "Safety Labels & Markings" for a table of factory-fitted warning labels. If any labels are missing, illegible or otherwise not functional, contact your supplier to obtain new replacement labels before operating the equipment. - Ensure all controls and switches are fitted firmly and are in good condition. If any are found to be loose or in poor condition, have an authorized service technician repair the unit before operating it.
	<p>CAUTION</p> <p>If any controls or switches are found to be loose or in poor condition, do not operate the equipment. Loose or damaged electrical controls and connections create a hazardous situation sufficient to cause serious injury or risk to life. Refer the equipment to an authorized service technician for repair.</p>
	<p>Over-Temperature Safety Cutout Test</p> <p>The over-temperature safety cutout should be tested periodically to ensure correct operation. This test should be conducted once every 2 years of normal operation.</p> <ul style="list-style-type: none"> - Turn off the On/Off mains power switch (element 6 in Figure 1). - Unplug the equipment from the mains power supply outlet. - Empty the water bath by referring to the section in this User Manual labeled "Emptying The Water Tank". - Fill the water tank with enough cold water to reach the level of the mesh platform by referring to the section in this User Manual labeled "Filling The Water Tank".
	<p>CAUTION</p> <p>NEVER touch the water tank or heating element whilst conducting the Over-Temperature Safety Cutout Test as serious burns and scalding could result.</p> <p>The test involves water reaching high temperature and the resulting steam present could cause serious burns or scalding.</p> <p>ALWAYS wear eye protection during the Over-Temperature Safety Cutout Test.</p> <p>ALWAYS maintain a safe working distance from the water bath during the Over-Temperature Safety Cutout Test.</p>
	<ul style="list-style-type: none"> - Connect power to the water bath as per the section of this User Manual labeled "Connecting Power". - Switch on the heating system as per the section of this User Manual labeled "Switching On The Water Heating". - Ensure the temperature set-point is set to 99.9°C, this ensures the heating element will remain on during the test. Refer to the section of this User Manual labeled "Setting the Required Water Temperature". - The water bath will begin heating the water and the Heating Element Indicator (element 8 in Figure 1) will light up.

	<ul style="list-style-type: none"> - Prepare 1000mL of cold water ready to fill the water tank on completion of the test. - The water in the water tank will gradually heat up. Do not leave the water bath unattended during the test. - After a period of less than a few minutes (depending on water level), the over-temperature cutout should activate. When the cutout activates, a small click sound may be heard and the Hot Surface Indicator (element 10 in Figure 1) light will flash. If the over-temperature cutout has failed to operate within 5 minutes, the test has failed and the water bath should be turned off immediately to prevent damage to the water bath. - Depending on the quality of the water being used, an unpleasant smell may also be noticed as a result of the impurities in the water becoming hot. This is normal. - Once the test has been completed, turn off power to the water bath by setting the On/Off mains power switch (element 6 in Figure 1) to the up position marked with a circle and refill the water tank with 1,000mL of cold water to cool the element by referring to the section in this User Manual labeled "Filling The Water Tank". This will help to maintain the working life of the heating element. - If the over-temperature cutout has failed to operate, contact Ratek using the contact details provided in the section of this User Manual titled "Ratek Service Contact Information".
	<p>CAUTION NEVER operate the water bath if the over-temperature safety cutout test has failed. Operating the water bath without a functional over-temperature safety cutout may result in serious injury, threat to life, fire or damage to property.</p>
	<ul style="list-style-type: none"> - Turn off the mains power supply at the outlet. - Allow the unit to cool for at least 10 minutes. - Refill the water tank by referring to the section in this User Manual labeled "Filling The Water Tank". - Connect power to the water bath by referring to the section in this User Manual labeled "Filling The Water Tank". - If the over-temperature safety cutout test passed, the water bath is now ready to be re-operated as per the section of this User Manual labeled "Switching On The Water Heating".

Technical Specifications

Temperature Controller	Digital PID using custom programmed microcontroller			
Temperature Sensor	Thermistor			
Temperature Range	Ambient +5° to 99.9°C (minimum 28°C)			
Safety	<ul style="list-style-type: none"> - Manual reset independent over temperature cut out - Fail safe thermal fuse - Mains over-current single-blow fuse - Element temperature limiting - Element guard 			
Mains Power Connection	240V / 50 Hz			
	WB200D	WB500D	WB1100D	WB1700D
Replaceable Fuse Type	F1AL250V (1 Amp) M205 miniature glass type	F3AL250V (3 Amp) M205 miniature glass type	F5AL250V (5 Amp) M205 miniature glass type	F10AL250V (10 Amp) M205 miniature glass type
Total Operating Wattage	170 Watts	550 Watts	930 Watts	1650 Watts
Overall Dimensions (mm)	L211xW185xH205	L375xW185xH205	L403xW335xH205	L581xW335xH205
Environmental Conditions	<p>Suitable for use according to IEC 61010-1 standard as follows :</p> <ul style="list-style-type: none"> - Indoor use - Altitude up to 2,000 Metres - Temperature 5° Celsius to 40° Celsius (Ambient temperature will limit the minimum achievable water temperature) - Maximum relative humidity 80 % for temperatures up to 31° Celsius decreasing linearly to 50 % relative humidity at 40° Celsius - MAINS supply voltage fluctuations up to ±10 % of the nominal voltage <p>Over-voltage Category – II Pollution Degree – 2</p>			

Disposal

At end of life, this equipment should be disposed of in an environmentally friendly way. This equipment cannot be disposed of with other general waste, but instead taken to your local or regional waste collection facility for recycling and/or suitable treatment procedure.

For more information about where you can drop off your waste equipment for recycling, please contact your local government office, your household waste disposal service or your nearest commercial recycling centre.

EMC Conformity



AS/NZS CISPR 14.1:2010 Electromagnetic compatibility - Requirements for household appliances, electric tools and similar apparatus – Emission. This forms the basis of compliance to the requirements of the Electromagnetic Compatibility Framework ('C TICK').

Ratek Service Contact Information

Ratek are here to assist you in getting the most from your Water Bath. Our friendly staff can you assist you at any stage of the product lifecycle.

If you have any concerns or questions regarding the operation of your Water Bath, please contact us.

	Contact Us
	Ratek Instruments Pty Ltd 60 Wadhurst Dve Boronia Victoria 3155 Australia Telephone : 613 9887 2161 Fax : 613 9887 2163 Email: sales@ratek.com.au Web: www.ratek.com.au

Troubleshooting

The Water Bath provides a simple-to-operate user interface when used in conjunction with this User Manual.

If at any stage you experience abnormal operation (anything other than that described in this Operating Manual) this may indicate a fault condition. If the Water Bath fails to operate, this may also indicate a fault condition.

Fault conditions must be referred to an authorized service technician immediately and the equipment should be unplugged from the mains power supply socket.

Make a written note of any abnormal operation and contact Ratek using the contact details provided in the section of this User Manual titled "Ratek Service Contact Information" if you believe your equipment is exhibiting a fault condition.

Warranty Conditions

This Ratek product is covered by a 3 year parts and 12 months labour return-to-base warranty effective from the date of purchase. The product is manufactured in Melbourne, Australia.

The warranty is offered by Ratek Instruments Pty. Ltd. located at 60 Wadhurst Drive, Boronia, Victoria, Australia 3155, phone number +613 9887 2161.

- This warranty covers the repair or replacement of any parts or components found to be defective, subject to the service options listed below.
- The warranty is a return-to-base warranty, meaning the product must be returned to Ratek Instruments or an authorised Ratek agent for service at the discretion of Ratek Instruments. Where practical an on-site repair may be carried out at the discretion of Ratek Instruments.
- This warranty excludes any defect resulting from misuse, neglect, accidental damage, improper voltage, operation of the product outside the acceptable operating conditions as indicated in these operating instructions or any alteration which affects the performance of the equipment.
- It does not extend to any costs associated with delivery of the product to or from Ratek Instruments or an authorised Ratek agent, damage, or loss incurred during transport.
- This warranty is in addition to any Statutory regulations and provisions implied by the Trade Practices Act and any relevant State or Federal Government obligations, applicable only when purchased within Australia.
- The product may be replaced within the warranty period at the discretion of Ratek Instruments, however repair will be the normal course of action.
- For a period of 3 years from date of purchase, replacement parts will be supplied at no charge and the original components returned to the repairer. These replacement parts may be installed by an approved service agent with prior written agreement from Ratek Instruments.
- For a period of 12 months from date of purchase, service labour and repairs will be carried out at no charge by an approved repairer or Ratek Instruments at the discretion of Ratek Instruments.
- The limit of liability shall extend to the repair of the product only, all other compensation claims are excluded from this guarantee.
- The warranty does not extend to claims of suitability where the product does not deliver the intended function or fails to operate.
- No claims of suitability are made in relation to the product by Ratek Instruments. Any claim of suitability lies with the operator.
- The product is used at the risk of the operator. Any loss or damage caused to any item used with the product including but not limited to biological samples, tubes, racks, accessories, flasks, containers or the contents of such containers caused by the malfunction of the product or the failure of the product to function is not covered by this warranty.
- Proof of purchase is required for all warranty repairs.

DOA Product

Any claim under this warranty must be made within 7 days of the date of purchase of the product. To make a claim under the Warranty, you must present the product, together with proof of purchase or issue, to the store where you purchased the product from. If the product is defective and does not meet the Warranty, you will be provided with a replacement product, or where that is not possible, a refund. Ratek Instruments will pay your reasonable, direct expenses of claiming under this Warranty. You may submit details and proof of your expense claim to Ratek Instruments for consideration.

This Warranty is provided in addition to other rights and remedies you have under law. Our goods come with guarantees that cannot be excluded under the Australian Consumer Law. You are entitled to a replacement or refund for a major failure and compensation for any reasonably foreseeable loss or damage. You are also entitled to have the goods repaired or replaced if the goods fail to be of acceptable quality and the failure does not amount to a major failure.

Return & Repair Procedures

The product is engineered from quality components designed to give long trouble-free operation. In the event that a technical problem has occurred that requires servicing by a Ratek Service agent, please follow these steps before returning the unit :

- Contact the supplier from where the equipment was purchased. If this is not possible, please contact Ratek Instruments either via email to service@ratek.com.au, or phone on +613 9887 2161 during business hours AEST. You may be referred to a local repair agent for service.
- Clean the unit thoroughly in accordance with this Operating Manual. If necessary, decontaminate the unit to ensure safety for the service technicians.
- Pack the unit into it's original packaging with the supplied mains power lead and use all original protective inserts. If the original packaging is not available, the unit must be packed with extreme care to ensure a safe journey. "Fragile" and "This Way Up" labels should be applied to the carton in a prominent location. No liability for a unit damaged in transit will be accepted. Use only reputable carrier services.
- Provide a full and complete fault description and your return contact details in the package and return the product as advised by the service representative.